



CITY OF EL RENO FIRE DEPARTMENT

Buildings Under Construction




Fires during construction, alteration, or demolition operations are an ever-present threat. The fire potential is inherently greater during these operations than in the completed structure due to the unprotected state of the structure, large quantities of combustible materials and debris, together with such ignition sources as temporary heating devices, cutting/welding/plumbers torch operations, and smoking. The threat of arson is also greater during construction and demolition operations due to the availability of combustible materials on site and the open access.

Fires during construction, alteration, or demolition operations can be eliminated or controlled through the early planning, scheduling, and implementation of fire prevention measures, fire protection systems, rapid communications, and onsite security.

The owner must designate a person to be responsible for the Fire Prevention program and development of a Fire Safety program that addresses at least the following:

- **Rapid Communications** – a means to report a fire (such as a telephone) on site. Post the street address of the construction site adjacent to the telephone.
- **Fire Department access** - Provide access to the job site for Fire Department apparatus from the start of the project through completion. The all-weather access roadway must extend to within 150' of all portions of the exterior walls of the building.
- **Lighted stairway** - Provide at least one temporary lighted stairway when construction extends to a height of 50' or more. Where necessary to clearly identify the exit pathway, provide appropriate exit signage including floor designations.
- **On-site security** – considerations should include secured perimeter, guarded entrance points, video surveillance and guard patrols.
- **Good Housekeeping** – accumulations of combustible waste material, dust, and debris shall be removed from the structure and its immediate vicinity at the end of each work shift or more frequently as necessary for safe operation.
- **Fire Protection Systems** – provide and maintain free access from the street to fire hydrants and to outside connections for standpipes, sprinklers, or other fire extinguishing equipment, whether permanent or temporary.
 - Hydrants – operational prior to any combustible construction
 - Standpipes – available for use during construction in buildings 4 or more stories before construction progress is more than 40' above the lowest level of Fire Department access.





- Fire Extinguishers – 2A10BC fire extinguishers (or larger) located in the following areas:
 - At each stairway on all floor levels
 - In every storage and construction shed
 - Where special hazards exist, including but not limited to the storage and use of flammable and combustible liquids
- Automatic Fire Sprinkler Systems – where a fire sprinkler system is to be installed, place the system in service as soon as practicable.
- **Extension cords** – maintain extension cords free from damage, removing all damaged equipment and cords from service.
- **Special Hazards**
 - Temporary heating equipment shall be listed, well maintained and monitored to assure continued safe operation. Clearances to combustible materials shall be maintained in accordance with its listing. Fuel supplies for LPG gas fire heaters shall comply with IFC Chapter 61.
 - Smoking – smoking shall be permitted only in designated areas and not in the vicinity of hazardous operations or combustible/flammable materials.
 - Storage & use of flammable and combustible liquids and flammable gases – storage of Class I and Class II liquids shall not exceed 60 gallons within 15’ of the structure. Storage areas shall be appropriately posted as “No Smoking” areas. These areas shall also be appropriately posted with marking in accordance with NFPA 704
 - Welding, grinding, roofing operations (hot asphalt or torch down) – A dedicated fire watch shall occur throughout the operations and continue for 30 minutes after conclusion. Prior to commencement of operations the area shall be clear of combustibles or the combustibles shall be protected.
- **Job/Dry shacks** – do not locate job/dry shacks in buildings under construction. A job/ dry shack must be separated from the building by not less than 20’ unless the building is equipped with a fire sprinkler system that has been placed in service has adequate emergency egress and ventilation provided.

Notes:

1. The fire department may require additional mitigation measures based on site/project specific issues.
2. If you have any questions need assistance or additional information, please contact the El Reno Fire Department at 405-262-2949.