



CITY OF EL RENO FIRE DEPARTMENT

Commercial Burning

The City of El Reno has adopted the 2015 International Fire Code, 2009 Life Safety Code and 2015 International Building Code. The 2015 IFC addresses open burning in section 307. In addition, to our city burn permit, commercial burning requires additional safeguards, as listed below.



1. Per DEQ any commercial burning shall have an air curtain incinerator. They must provide specific requirements for each air curtain incinerator. This will include how wide and deep the burn pit must be.
2. Onsite inspection must occur to determine if site will create or adds to a hazardous situation.
3. All burning must be 50' away from structures. Where pile is over 6'x4', the fire code official is authorized to require additional distance from structures.
4. Open burning must be extinguished 3 hours before dark. Open burning may be allowed after sunset if authorized by the fire code official.
5. Personnel shall always be onsite and maintain an approved water source for extinguishment.
6. Daytime and night time contact numbers must be given the fire department.