



CITY OF EL RENO FIRE DEPARTMENT OUTDOOR FIRE PITS

- **Manufactured fireplaces and fire pits shall be used in accordance with manufacturer's instructions and shall not be operated within 15 feet of a structure or combustible material.**
- **A fire pit shall be a substantial structure with some type of permanent perimeter. The surrounding area shall be free of vegetation and combustible material.**
- **No barrels, buckets or similar containers shall be allowed. A hole in the ground with rocks around the perimeter shall not be considered a fire pit.**
- **Burning in an outdoor fireplace or fire pit shall be done responsibly and shall not be allowed when local circumstances such as high fire danger is in effect.**
- **Burning that is objectionable because of smoke emissions shall be prohibited.**
- **Materials to be burned shall be firewood or propane. Tree limbs generated on the premises shall also be allowed.**
- **The fire pit cannot be larger than 3-foot-wide by 2-foot-tall.**
- **Fires shall be constantly attended until extinguished.**
- **Leaves, paper, trash, plastic or lumber of any kind shall not be allowed.**
- **One 4-A extinguisher or garden hose shall be available and in the immediate vicinity for extinguishment.**
- **The officer in charge or his designee shall make the determination as to whether smoke emission or conditions warrant extinguishment. 2015 IFC 307.3**