



## CITY OF EL RENO FIRE DEPARTMENT

### **Above ground LPG Portable Storage Tank at RV and or Mobile Home Parks**

Above Ground LPG Storage Tanks- Shall be no more than 125 (water gallons)

1. IFC 2015 Table 6104.3- LPG containers shall be located with respect to buildings, public ways, and lot lines adjoining property that can be built upon.
  - A. May not be stored under the occupancy.
  - B. Pressure Relief Valve shall be directed away from dwelling and 5' from exterior ignition sources.
  - C. Filling connection must be at least 10' away from exterior sources of ignition.
  - D. There shall be a minimum separation of 5' from lot lines/property lines.
  
2. NFPA 58 Section 6.6- Protection and Mounting of LPG Storage tanks.
  - A. If tank is within 10' of vehicular traffic, tank shall be protected by a vehicular barrier.
  - B. Above ground storage tanks shall be painted.
  - C. The cylinder shall be mounted on a firm foundation and not come in contact with soil.